

**PUD NO. 1 OF SKAGIT COUNTY  
COLLEGE WAY: URBAN TO LAVENTURE PIPELINE REPLACEMENT PROJECT**

**ADDENDUM NO. 5**

Date of Issue: January 24, 2025

**To All Planholders and/or Prospective Bidders:**

**The time and place of bidding** is 10:00 AM, Wednesday, February 5, 2025, at Public Utility District No. 1 of Skagit County.

A **pre-bid meeting** will be held at 10:00 AM, Wednesday January 29, 2025, at Public Utility District No. 1 of Skagit County. This pre-bid meeting will NOT be mandatory for bidding.

Acknowledge receipt of this Addendum in the space provided in the BID FORM. Failure to do so may subject the Bidder to disqualification.

The following changes, additions, and/or deletions are hereby made a part of the project bid documents for the College Way: Urban to LaVenture Pipeline Replacement Project, and shall have the same effect as if set forth therein.

**A. INSTRUCTION TO BIDDERS**

- a. Delete the following “This work to be done during the evening and overnight hours” and replace with the following “This work to be done during normal day time hours”.

**B. TECHNICAL SPECIFICATIONS**

- a. Section 01010 – Summary of Work
  - i. Delete the following “This work to be done during the evening and overnight hours” and replace with the following “This work to be done during normal day time hours”.
- b. Section 01313 – Construction and Schedule Constraints.
  - i. Delete Table 1 and replace with the following:

<b>TABLE 1 CONSTRUCTION TIMING CONSTRAINTS SUMMARY</b>		
<b>Location/ Jurisdiction<sup>(1)</sup></b>	<b>Activity</b>	<b>Constraints<sup>(2)</sup></b>
City of Mount Vernon	Construction Hours	7 AM – 9 PM, Monday through Friday 8 AM – 9 PM, Saturday and Sunday To work outside of normal hours, a request must be submitted to the City of Mount Vernon. The City Official will review and issue a written approval (administrative process).
PUD No. 1 of Skagit County	Connection to Existing Pipeline	Provide 3-day Notice prior to start of work Tie in Notification Service Connection

	Project Phasing Customers	<ul style="list-style-type: none"> <li>• Reflect Project Phasing in Order of Operation and on Schedule</li> <li>• Give Customers 24 hours notice that water will be shut off to property in order to make connections to existing mainlines.</li> </ul>
<p>Notes:</p> <p>(1) Per locations noted on drawings.</p> <p>(2) Unless otherwise noted, a time period is when construction can occur. If there is a conflict between permits/approvals, the more restrictive constraint will apply.</p> <p>(3) Attached in Appendix C is a copy of the Archaeological Inadvertent Discovery Plan. In the event of such a discovery the Contractor shall comply with the plan.</p>		

**C. RESPONSE TO QUESTIONS**

Question	Response
Since the alignment changed with Addendum #4, is the work still to be done during night hours or can it be done during the day?	Work hours will now be during the day.
Clarification regarding Contractors responsibility for the lump sum items for tie-ins.	The Contractor is responsible for, but not limited to, excavation, shoring, backfill, thrust blocking, removal and disposal of asphalt, disposal of excess soils, dewatering for District crew to make final connection to existing pipelines, ditch and landscape restoration, and survey and construction staking. Cold patch, asphalt patching, saw cutting and crushed surfacing top course shall be paid as separate units of work. District crews will provide pipe materials for tie-ins in accordance with the plans.

This Addendum consists of a total of **two (2) pages**.



01/24/2025

Mark C. Handzlik, P.E., Engineering Manager